



**ADDENDUM #1 – IFB-3039-02/GMG
Term Contract for Fire Extinguisher Services**

The following information constitutes Addendum #1 and becomes part of the original bid package.

I. Page 16: Delete lot # 2 #9 we no longer have fire hoses in any of our buildings.

II. Answers to questions submitted by A-1 Fire Equipment, Miami:

Q. 1. Lot 1, #1, item a & b: what does the unit price comprise of: annual inspection? 6 year maintenance? recharge? hydro test? or a combination of some or all of these services?

A1 These are annual inspection prices

Q. 2. Lot 2, #1, item a,b,c & d: what does the unit price comprise of: a recharge + a hydro test + a general repair and service for each extinguisher? (normally, not all these services are necessary for all the units!). What about the annual inspection certification?

A2 lot # 2 cost is for material only

Q.3 Lot 2, #2, item a,b,c,d,e,f, & g / Lot 2, #3, item a & b / Lot 2, #4, item a,b,c,d & e: what do you mean by "pressurize"? Do you mean "recharge"? If so, do you want us to include a recharge price for each unit? The NFPA code requires a recharge with each 6 year maintenance, 12 year maintenance and obviously after use and/or discharge.

A3 lot # 2 Annual inspection cost, recharge when necessary only which is included in other section of bid.

Q.4 Lot 2, #9, item a & b: does the unit price include a hydro test for each hose? The NFPA code requires a hose hydro test 5 years after initial installation, and every 3 years thereafter. In order to determine and quote "Test when necessary", we need to know the age of all the hoses, or please, suggest alternative pricing method.

A4 lot # 2 #9 should be omitted we no longer have fire hoses in any of our buildings. (as stated above in Item I. of this Addendum)

Q.5 Lot 3, item 1: Please specify how many tanks per automatic hood system?

A5 lot # 3, one tank

Q.6 Lot 4, item 1 & 2: Please specify what halon "PODS" are? Also please note that Halon is a substance now banned by the EPA. We use a "halon alternative" product such as "Halatron".

A6 lot # 4 "PODS" are units located over all the cooking areas, one in each fire station, the jail. the Cooperative Extension Auditorium etc. an alternative product is acceptable.

As acknowledgment of receipt of Addendum, attach this addendum immediately behind the Bid Response Form. Failure to acknowledge receipt of this addendum may result in disqualification of your bid submittal.

COMPANY NAME: _____

AUTHORIZED SIGNATURE: _____

DATE: _____

Gloria M. Garcia
Gloria M. Garcia, CPPB
Senior Buyer